

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 6911-1493:145 Page 1 of 1

CATEGORY: Voice Communication System Control Units

LISTEE: *Grinnell Fire Protection Systems, 835 Sharon Dr., Westlake OH 44145
Contact: R.D. McDonnell (216) 871-9900

DESIGN: EMERCOM 200 system. Provides one-way voice communications, single or dual channel, public address with 4-tone options to alert for fire emergency and message repeater module for prerecorded general instructions; and two-way firefighter's phone communication. Refer to the listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a stand-alone voice communication and firefighter's phone system. May be interfaced with Model FC-72 control unit (CSFM Listing No. 7165-0694:001).

NOTE: 1. When used as a stand-alone system or with listee's fire signaling system, the EMERCOM 200 is NOT acceptable for use as part of a high-rise fire alarm system.

2. Formerly 6911-0062:159

XLF: 6911-0694:129

*Rev. 09-30-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 19, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy
Program Manager